CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0067:205 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932

Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

DESIGN: Strobe Lights U-S17, U-S17-C, U-S17-W, U-S17-W-C

> U-S30, U-S30-C, U-S30-W, U-S30-W-C U-S60, U-S60-C, U-S60-W, U-S60-W-C U-S75, U-S75-C, U-S75-W, U-S75-W-C U-S110, U-S110-C, U-S110-W, U-S110-W-C

U-S17-6090V, -W, U-S30-6090V, -W U-S60-6090V, -W, U-S75-6090V, -W

U-S110-6090V, -W

Synchronized U-S17S, U-S17S-C, U-S17S-W, U-S17S-W-C Strobe Lights U-S30S, U-S30S-C, U-S30S-W, U-S30S-W-C

> U-S60S, U-S60S-C, U-S60S-W, U-S60S-W-C U-S75S, U-S75S-C, U-S75S-W, U-S75S-W-C U-S110S, U-S110S-C, U-S110S-W, U-S110S-W-C

U-S17S-6090V, -W, U-S30S-6090V, -W U-S60S-6090V, -W, U-S75S-6090V, -W

U-S110S-6090V, -W

All synchronized strobes must be used with Models SCM-F, SCM-FW, DSC or DSC-W Sync Modules. Refer to listee's data sheet for additional detailed product description, electrical

rating and operational considerations.

RATING: Electrical: 20-31 VDC

Candela: -S17, -S17S (15/75cd); -S30, -S30S (30/75cd);

-S60, -S60S (60/75cd); -S75, -S75S (75cd); -S110, S110S (110cd)

Flash Rate: 60 flashes/min

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and

in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired when used in conjunction with separately

listed compatible audible signal devices and fire alarm control units. All units are suitable for wall

or ceiling mounted. For indoor use only.

XLF: 7125-0065:154

*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

OCTOBER 26, 2002 Date Issued: Listing Expires June 30, 2003

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager